

Test Report No. VNHL1907011676HG

Date: August 21, 2019

Page 1 of 3

AN CUONG HIGH-TECH BUILDING MATERIALS JSC

AN PHAT HI-TECH INDUSTRIAL PARK, HAI DUONG CITY, VIET NAM HANOI SHOWROOM: 3RD FLOOR, NO 285 NGO GIA TU STR., LONG BIEN DIST., HA NOI, VIET NAM

The following sample was submitted and identified on behalf of the client as below:

SGS Job No.	:	VNHL1907011676HG
Sample Description	:	ANPRO SPC FLOORING
Buyer	:	CONG TY CO PHAN VAT LIEU XAY DUNG CONG NGHE CAO AN CUONG
Manufacturer	:	AN CUONG HIGH-TECH BUILDING MATERIALS JSC
Characteristic	:	"PVC+BOT DA+PHU GIA"
Country of Origin	:	VIETNAM
Sample Receiving Date	:	JULY 12, 2019
Final confirmed Date	:	JULY 12, 2019
Testing Period	:	JULY 12, 2019 TO AUGUST 21, 2019
Test Requested	:	PLEASE REFER TO THE RESULT SUMMARY.
Test Results	:	PLEASE REFER TO NEXT PAGE(S).
Result Summary	:	

Test Requested	Conclusion
Staining Resistance (Resistance to Chemicals)	Data / See results

Signed for and on behalf of SGS Vietnam LTD



Wong Cho Wing Hardline and E&E Lab Manager

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 90 days only

SGS Vietnam Ltd

HCM Office: 198 Nguyen Thi Minh Khai St, District 3, Ho Chi Minh City, Vietnam t (84-28) 3935 1920 f (84-28) 3935 1921 www.sgs.com Hai Phong Branch: Workshop X11, Hai Thanh Workshop Area, Hai Thanh Ward, Duong Kinh District, Hai Phong City, Vietnam t (84-225) 355 2722 f (84-225) 355 2724

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions of the company subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions of the company subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions of the company subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions< Document.aspx

Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law



Test Report

No. VNHL1907011676HG

Page 2 of 3

Test results:

Sample description: ANPRO SPC FLOORING 153.4MM X 153.4MM

1. Test item: Resistance to Chemicals

Test method: ASTM F925-13

Test condition:

Specimen: 153.4mm×153.4mm×5.6mm, 12pcs

Treatment time: 1h

Lab environmental condition: 23±2°C, 50±5%RH

Test result:

Test item	Test chemical	Test result
Resistance to Chemicals	White vinegar (5% acetic acid)	No visual change
	Rubbing alcohol (70% isopropyl alcohol)	No visual change
	White mineral oil (medicinal grade)	No visual change
	Sodium hydroxide solution (5% NaOH)	No visual change
	Hydrochloric acid solution (5% HCl)	No visual change
	Sulfuric acid solution (5% H ₂ SO ₄)	No visual change
	Household ammonia solution (5% NH4OH)	No visual change
	Household bleach (5.25% NaOCI)	No visual change
	Phenol (5% active phenol)	No visual change
	Kerosene (K1)	No visual change
	Olive oil (light)	No visual change
	Unleaded gasoline (regular grade)	No visual change

Remark: This / these test(s) was / were performed by SGS China Lab.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 90 days only.

SGS Vietnam Ltd


HCM Office: 198 Nguyen Thi Minh Khai St, District 3, Ho Chi Minh City, Vietnam t (84-28) 3935 1920 f (84-28) 3935 1921 www.sgs.com Hai Phong Branch: Workshop X11, Hai Thanh Workshop Area, Hai Thanh Ward, Duong Kinh District, Hai Phong City, Vietnam t (84-225) 355 2722 f (84-225) 355 2724

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions of electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions of electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-and-Conditions for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-and-Conditions/Terms-and-Conditions/Terms-and-Conditions of the state of the s

Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



Test ReportNo. VNHL1907011676HGDate: August 21, 2019Page 3 of 3PHOTO OF SUBMITTED SAMPLE FOR TESTING



REPORT RESULTS REFER TO SUBMITTED SAMPLE (S) ONLY *** End of Report ***

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions of electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions of electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-and-Conditions for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-and-Conditions/Terms-and-Conditions/Terms-and-Conditions of the state of the s

Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 90 days only.

SGS Vietnam Ltd

HCM Office: 198 Nguyen Thi Minh Khai St, District 3, Ho Chi Minh City, Vietnam t (84-28) 3935 1920 f (84-28) 3935 1921 www.sqs.com Hai Phong Branch: Workshop X11, Hai Thanh Workshop Area, Hai Thanh Ward, Duong Kinh District, Hai Phong City, Vietnam t (84-225) 355 2722 f (84-225) 355 2724