

# An Phat Bioplastics Joint Stock Company

## TEST REPORT

**SCOPE OF WORK**

Luxury Vinyl Flooring

**REPORT NUMBER**

260508015SHF-001

**TEST DATE(S)**

2026-05-08 - 2026-05-14

**ORIGINAL ISSUE DATE**

2026-05-15

**PAGES**


5

**DOCUMENT CONTROL NUMBER**

LFT-APAC-SHF-OP-10k(January 13, 2025)

© 2025 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



## Test Report

### Statement

- 1.This report is invalid without company's special seal for testing on the assigned page.
- 2.This report is invalid without an authorized person's signature.
- 3.This report is invalid if altered.
- 4.Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Don't copy this report in partial without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.
- 6.Except for the obligation, responsibility and liability (if any) for the appropriateness and professionalism of afore-mentioned testing itself within the scope and amount of the testing fee received, Intertek does not and will not accept any other obligation or liability.
- 7.If the Client has any questions about the test results, Intertek B&C should be informed within the storage period of the samples. The sample storage period ends 5 working days after the official report issue date. Samples of certification program are retained for the period required by the certification rules. The samples storage period shall be calculated according to the issue date of the original report in the case of quoting results and modifying reports.
- 8.Intertek B&C will service this report for the entire test record retention period. The test record retention period ends 6 years after this report original issue date. The test record retention period for certification program is 10 years. Test records and other pertinent project documentation will be retained for the entire test record retention period.
- 9.The report was digital signed by Shang Hai, Intertek Group plc, please using Adobe Acrobat Reader to verify the authenticity.



## Test Report

Original Issue Date: 2026-05-15

Intertek Report No. 260508015SHF-001

Applicant: An Phat Bioplastics Joint Stock Company

Address: Lot CN11+ CN12, An Dong Industrial Park Nam Sach Commune, Hai Phong city, Vietnam

Attn: Pham Tien Dung

Manufacturer: An Phat Bioplastics Joint Stock Company

Address: Lot CN11+ CN12, An Dong Industrial Park Nam Sach Commune, Hai Phong city, Vietnam

Test Type: Performance test, samples provided by the applicant.

### Product Information

Product Name	Model	Specification
Luxury Vinyl Flooring	LVT Flooring	50.8mm*50.8mm*2mm
Sample ID	Sample Amount	Sample Received Date
S260508015SHF.001	3pcs	2026-05-08
Sample Description		
50.8mm*50.8mm*2mm		

### Test Methods And Standards

Test Standard	ASTM F970-22
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report does not involve sampling. The report only reflects conformity of the tested items of the samples provided by the testing applicant. Representativeness and authenticity of the submitted samples are responsibilities of the testing applicant.

### Report Authorized

Flora Fan

Name: Flora Fan

Title: Reviewer



Roger Chen

Name: Roger Chen

Title: Project Engineer

# Test Report

Original Issue Date: 2026-05-15

Intertek Report No. 260508015SHF-001

### Test Items, Method and Results:

Test Item: Static load resistance

Test Method: ASTM F970-22

Conditioning: Condition the test specimens at  $(23 \pm 2)^{\circ}\text{C}$  and  $(50 \pm 5)\%$  relative humidity for at least 24h

Test Condition:

Indenter diameter: 28.6 mm  
Total load applied: 250 lb / 250 psi  
Indentation time: 24 h  
Recovery time: 24 h

Test Result:

Residual Indentation	Result (mm)
Specimen 1	0.03
Specimen 2	0.01
Specimen 3	0.03
Average value	0.02
Max. value	0.03




## Test Report

Original Issue Date: 2026-05-15

Intertek Report No. 260508015SHF-001

### Appendix A: Sample Received Photo



### Revision:

NO.	Date	Changes
260508015SHF-001	2026-05-15	First issue